



REMOVE EXISTING ELECTRIC RANSE PER CITY FIRE DEPARTMENT

DOOR LOT REQUIRED TO SWIMS OUT WHEN SERVING FEWER THAN 50 OCCUPANTS IBC 2006 1028.1.2.

SEE ATTACHED STRUCTURAL ENGINEERING REPORT FOR RECOMMENDED CHANGES TO DECK STRUCTURE

EGRESS PATH
47-94 STEPS CAN SERVE UP TO 192 OCCUPANTS PER TABLE 1025.1

ACCESSIBLE EGRESS PATH
42-94 STEPS CAN SERVE UP TO 210 OCCUPANTS PER TABLE 1025.1

CHANGE DOORS TO SWIMS OUT WITH PLASTIC HARDWARE

EAT WIDTH PROVIDED

EGRESS WIDTH FROM OUTDOOR DECK CAN SUPPORT UP TO 340 OCCUPANTS. FACILITY MAX. OCCUPANT LOAD = 166

F.E. = FIRE EXTINGUISHER, WALL-MOUNTED OR